

8.1 Interior Wood Doors.

A. General Requirements

1. Submit shop drawings.
2. Follow approved manufacturer's printed instructions.
3. Utilize solid core commercial wood doors only, fire rated and fire labeled where required by code to be thus.
4. All door framing within a metal stud wall shall feature double studs at both jambs and the head of the door, securely screwed together.

B. South Campus

1. Utilize a facing of plastic laminate. No paint; no natural finish. Plastic laminate shall be equal to Wilson Art. Supply extra edge strip stock for future door repairs in each order. Color shall be similar and complementary to the existing colors, or for new construction shall be as approved by campus administrators.

C. North Campus

D. Kent Campus

1. Utilize a facing of wood veneer. White oak to match campus is preferred. Birch is acceptable where door is low visibility. 1 coat stain, or no stain, to match nearby doors. Two to three coats of oil based clear urethane finish. Lightly sand urethane between coats with #150 aluminum oxide sandpaper.

E. Downtown Campus

1. No plastic laminate door finish allowed. Utilize a facing of birch veneer. 1 coat stain to match nearby doors. Two to three coats of oil based clear urethane finish. Lightly sand urethane between coats with #150 aluminum oxide sandpaper.

F. Deerwood Center

1. Utilize a facing of laminate or birch to match nearby doors.