

8.3 Aluminum Storefront Doors and Fixed Glass

A. General Requirements

1. Submit shop drawings.
2. Vertical mullions shall not exceed 5 feet on center.
3. In general, storefront sections shall utilize a rail member at 24" above finish floor.
4. Pay attention to code requirements for tempered or other specialty glass such as laminated glass.
5. Generally, storefront units shall be center glazed rather than face glazed systems.
6. Where insulated glazing units are scheduled to be used, glazing unit shall be of the high performance type: Evacuated hermetically sealed units which feature tinted glass in the outer layer, and a Lo E coating on Surface #3 of the insulated glazing unit.

B. South Campus

1. Utilize Kawneer Trifab 350 in bronze anodized finish to match existing.
2. Doors shall be 7'-0" in height with transom to match height of storefront system.

C. North Campus

D. Kent Campus

1. Utilize Kawneer Trifab 350 in bronze anodized finish to match existing.

E. Downtown Campus

1. Utilize Kawneer Trifab 350 in bronze anodized finish to match existing.